


STREET LIGHT

INSTALLED IN THE TRENCH LINE




STREET LIGHT  
STREET LIGHT SECONDARY GROUND SLEEVE

STREET LIGHT 6' BEHIND GROUND SLEEVE




SECONDARY GROUND SLEEVE

GROUND SLEEVE 6' BEHIND WALK




SECONDARY GROUND SLEEVE  
STREET LIGHT

STREET LIGHT IN THE TRENCH LINE  
18' BEHIND WALK OR CURB  
6' EITHER SIDE OF GROUND SLEEVE




TRANSFORMER GROUND SLEEVE




TRANSFORMER GROUND SLEEVE  
SECONDARY GROUND SLEEVE

TRANSFORMER SLEEVE 6' BEHIND WALK  
ELEVATION 4' ABOVE WALK




TRANSFORMER GROUND SLEEVE  
STREET LIGHT

TRANSFORMER SLEEVE 6' BEHIND WALK  
ELEVATION 4' ABOVE WALK



TRANSFORMER GROUND SLEEVE  
SECONDARY GROUND SLEEVE  
STREET LIGHT

TRANSFORMER SLEEVE 6' BEHIND WALK  
ELEVATION 4' ABOVE WALK



UPRIGHT PRIMARY JUNCTION  
GROUND SLEEVE  
(1 PHASE & 3 PHASE)

12 - 18' BEHIND WALK  
PL —  
ELEVATION 4' ABOVE WALK

FLUSH PRIMARY JUNCTION  
GROUND SLEEVE  
(1 PHASE & 3 PHASE)

12 - 18' BEHIND WALK  
PL —  
ELEVATION 4' ABOVE WALK



EQUIPMENT  
ALIGNMENT ON TRENCH

REV.

700-05

SCALE: NA

POWER & COMMUNICATIONS

DATE: DECEMBER 2003

DRAWN BY: RAWTMF

APPROVAL: