



TO PREVENT ENTRANCE OF WATER INTO CABLE, COLD SHRINK SHALL BE INSTALLED ON THE ENDS OF ALL PRIMARY CONDUCTORS



COLD SHRINK INSTALLATION

REV.

700-08

SCALE: NA

POWER & COMMUNICATIONS

DATE: DECEMBER 2003

DRAWN BY: RANTMF

APPROVAL: