


1. CONCRETE BASE MUST BE LEVEL
2. SET 4" ABOVE FINAL GRADE
3. INSTALL AN 8' GROUND ROD & #4 COPPER
4. PROVIDE 95% COMPACTION UNDER AND AROUND THE CONCRETE BASE

	STREET LIGHT BASE		
	REV. 2 1/10/05	700-14	SCALE: NA
POWER & COMMUNICATIONS	DATE: DECEMBER 2003	DRAWN BY: RAWTMF	APPROVAL: