


UTILITY GROUND SLEEVE

APPLICATION:

LOCATIONS WHERE MORE THAN TWO RESIDENTIAL SERVICE LATERALS TAKE OFF FROM A SECONDARY JUNCTION FACILITY OR FOR MULTI FAMILY OUT OF A TRANSFORMER.

1. SERVICE LATERAL CONDUCTORS SHALL BE CUT A LENGTH THAT ALLOWS THEM TO EXTEND 30" ABOVE THE JUNCTION BOX LID OR 49" ABOVE THE TRANSFORMER GROUND SLEEVE
2. ALL CONDUCTORS OF EACH SERVICE LATERAL SHALL BE MARKED USING HEAT SHRINK TUBING WITH A COLOR THAT IS UNIQUE TO THE UNIT IT SERVES
3. THE COLOR IDENTIFIER SHALL BE AT LEAST 4" LONG AND SHALL BE PLACED 18" ABOVE THE JUNCTION BOX LID OR GROUND SLEEVE.
4. CONDUCTORS SHALL ALSO BE MARKED IN THE METER HOUSING USING COLORED HEAT SHRINK THAT IS AT LEAST 1 INCH LONG
5. THE COMPACTION UNDER AND AROUND THE GROUND SLEEVE MUST BE RESTORED TO 95% AFTER THE INSTALLATION OF THE SERVICE LATERAL

	<p>SERVICE LINE IDENTIFICATION</p>		
	REV.	700-15	SCALE: NA
	POWER & COMMUNICATIONS	DATE: DECEMBER 2003	DRAWN BY: RANTMF APPROVAL: